

# Safety Challenges and Solutions LANSCCE

## DTL Cracked Weld Repair

Michael Borden (+57 other people)

LANL AOT-MDE GL

9-11-2019

# LANSCCE is a unique national user facility running five experimental facilities

Lujan Neutron Scattering Center

Weapons Neutron Research Facility


Isotope Production Facility



Proton Radiography

800 MeV Proton Linear Accelerator  
Ultra Cold Neutron

# Photos from Original Build



*Drift tube installation*


*Inside of tank - drift tubes and post couplers*

# Recent Module 3 Operating Parameters Indicates Degradation with Time


| Date       | PRF | RF Gate Length | Beam Pulse | Average RF Power |
|------------|-----|----------------|------------|------------------|
|            | Hz  | usec           | usec       | kW               |
| 7/16/2017  | 120 | 1010           | 625        | 153.75           |
| 11/16/2017 | 120 | 810            | 475        | 116.85           |
| 11/17/2017 | 120 | 830            | 525        | 129.15           |
| 11/27/2017 | 120 | 830            | 565        | 138.99           |
| 6/28/2018  | 120 | 880            | 625        | 153.75           |
| 9/18/2018  | 120 | 760            | 520        | 127.92           |
| 9/20/2018  | 120 | 700            | 400        | 98.4             |
| 9/24/2018  | 60  | 1010           | 625        | 76.875           |
| 9/24/2018  | 60  | 1060           | 625        | 76.875           |
| 9/26/2018  | 60  | 1060           | 725        | 89.175           |
| 10/9/2018  | 60  | 1040           | 725        | 89.175           |

# LANSCCE Alvarez Drift Tube LINAC (DTL)

- 201 MHz DTL is upstream of all experimental areas – all areas were offline (Module 3 ~ 60' long)
- Crack near ion pump grate in Module 3 prohibits RF induced longitudinal currents from flowing continuously in the copper cladding causing high-voltage breakdown
- Crack was approximately 12 inches long at the grate to copper cladding weld joint (is not a structural tank weld)



# Non-Intrusive Low Risk Options were Installed Through the Ion Pump Grate





*Copper tape applied to crack –  
Was tried first and conclusively  
proved that the source of the  
breakdown was indeed the crack.  
Tape blistered after a few hours at  
full power.*

*Copper bridge with RF fingerstock  
bridging the crack -  
Two versions were installed and  
tried, but were not successful in  
preventing high voltage breakdown  
Decision is made must enter the  
tank and repair the crack*

# Copper Bridge To Be Welded Over The Crack

NOTES: (UNLESS OTHERWISE SPECIFIED)

- ENGINEERING DRAWING DOCUMENTATION IN ACCORDANCE WITH:
  - GLOBAL ENGINEERING DRAWING REQUIREMENTS MANUAL 11TH EDITION.
  - DIMENSIONING AND TOLERANCING PER ASME Y14.5-2009.
  - ABBREVIATIONS IN ACCORDANCE WITH ASME Y14.38A-2007.
  - SURFACE TEXTURE SYMBOLS IN ACCORDANCE WITH ASME Y14.36M-1996 (R2008). SURFACE TEXTURE IN ACCORDANCE WITH ANSI/ASME B46.1-2009.
  - STANDARD SYMBOLS FOR WELDING, BRAZING, AND NONDESTRUCTIVE EXAMINATION ANSI/AWS A2.4-2012.
- ALL DIMENSIONS ARE IN INCHES.
- REMOVE ALL BURRS AND BREAK SHARP EDGES TO A MAX .02.
- COUNTER SINK TAPPED HOLES TO MAJOR DIAMETER.
- ALL INSIDE CORNERS TO BE R.02-R.04.
- PART IS TO BE THOROUGHLY CLEANED TO REMOVE ALL OIL, DIRT, GREASE AND CHIPS.
- DIMENSIONAL LIMITS APPLY IN THE FLAT.
- APPROXIMATE WEIGHT: 0.745 LBS.




SECTION A-A  
SCALE 4 : 1

|                             |                |   |   |
|-----------------------------|----------------|---|---|
| AR                          | SHEET OR PLATE | OFHC C10100 PER ASTM B 152                            | 1 |
| PART NUMBER OF THIS DRAWING |                | PART DESCRIPTION                                      |   |
| PARTS LIST                  |                | PROJECT   |   |
| DTL TANK 3                  |                | Los Alamos NATIONAL LABORATORY MECHANICAL ENGINEERING |   |
| APPROVALS                   |                | TITLE   |   |
| J. Martinez 08/19/19        |                | ION PUMP GRILLE CRACKED WELD COPPER BRIDGE            |   |
| SCALE 1:1                   |                | FORM NO. 88516  |   |
| DATE 08/19/19               |                | REV. 1  |   |
| DRAWN BY                    |                | PART NUMBER   |   |
| CHECKED BY                  |                | 88516   |   |
| DESIGNED BY                 |                | SK-M-DTL3-061819-01                                   |   |
| MATERIAL                    |                | SCALE 1:1   |   |
| SHEET 1 OF 1                |                | ISSUED BY   |   |

# Preparing to Enter Tank 3 Through End to Weld Bridge over Cracked Weld


- Tank head had to be removed to allow welder to enter and perform the repair (Spider Crane)
- Frequency tuners and post couplers on the aisle side and #116 at the repair area are removed
- Alignment data was acquired for post couplers and drift tubes for 14 of 18 drift tubes
- Performed mock up of tank and practiced welding to simulate actual conditions
- Full PPE dress was used while welding in Mock-up
- Multiple check lists were developed and walked down and refined during Mock-up




*Upstream End Wall of Tank 3*



# Frequency Tuners – port size 5.75 inches



*Active frequency tuner*



*Passive frequency tuner*

# Integrated Work Document IWD – Hazard ID

- Confined Space
  - person will enter a confined space, a 35 inch diameter pipe, to a location near the second ion pump grate, about 23 feet from the only entry and exit point
  - there is limited mobility in the confined space especially with regard to maneuvering:– must shimmy in and out on torso to clear drift tubes
- Welding
  - copper vapor exposure limits
  - welding in the prone (face down) position affects ability to see and guide the welding gun
  - radioactive base metal (1/8” copper cladding)
  - Protection from hot surfaces
  - Tig welding plasma is an ignition source

# Integrated Work Document IWD – Hazard ID

- Breathing
  - available oxygen is displaced by CO<sub>2</sub> exhaled, Helium welding cover gas
- Communication
  - affected by the wearing of a respirator
  - affected by the limited number and size of ports to external personnel

# Industrial Hygiene estimates and measurements

- Module 3 Ventilation High Points
- Airborne copper fume. Permissible Exposure Level (PEL) =  $0.1 \text{ mg/m}^3$  (8 hour exposure)
- Volume of space 250 cubic feet
- Air supply 1,000 CFM
- Calculated maximum copper fume =  $0.45 \text{ mg/m}^3$
- Dependent on 2.5 FPS (150 FPM – 1,000 CFM) air flow. Measure this flowrate in real time using calibrated anemometer and adjust calculated value accordingly.
- Sample results on mock-up were  $0.43 \text{ mg/m}^3$

# Radiation Protection Assessment

- **Hazard assessment**

- Work history (present and past) on the interior surface of the module 3 tank and associated beamline components were less than 1000 dpm/100 cm<sup>2</sup> (majority NDA).
- Highest dose rate in the module 3 tank is 50 mrem/hr on contact at the tank entry (open) area; dose rate at the location of the weld 1 mrem/hr on contact.
- Estimate of airborne radioactivity from welding: 0.8 DAC
  - MicroShield estimate of airborne radioactivity based on a dose rate of 2 mrem/hr on contact (actual dose rate 1 mrem/h).
  - Gamma spectroscopy of tank identified radionuclides: Zn65 and Co60
- Test weld Mock- Up
  - Activated copper sample – radiological characteristics
    - Fixed contamination: 1900 dpm/100cm<sup>2</sup> beta/gamma
    - Dose rate : 0.1 mrem/h on contact
  - Air samples collected from the worker's breathing zone and LEV.
    - Gamma spectroscopy: NDA
    - Gross alpha/beta: NDA
  - No work area or personnel contamination detected.
  - Sample radiological characteristics unchanged following the test weld.

# Sample Configuration for Radioactive Welding

- *HEPA Vacuum ventilation in cone*
- *Sampling unit in cone*
- *Sampling unit in work area*
- *Welder full anti-C PPE and full face respirator*



# Radiation Protection Assessment

- **Hazard Controls**
- Respiratory protection – none required
  - DAC less than 1
  - Air monitoring is not required ( $HI < 2$ ), however, low volume samplers were placed in the module 3 tank tuner slug port opening and general work area (post repair all nda).
- Anti-contamination clothing
  - Coveralls with rubber booties selected for the industrial hazard (spark & flame resistant) rated and approved – Level I anti-C.
  - Skull cap/hood required
  - Gloves – Leather welding gloves
- Job coverage
  - RWP - Continuous RCT coverage

# Integrated Work Document IWD – Controls

- Confined Space
  - confined space permit
  - Attendant IH continuous
  - rescue plan, rescue attachments: ankles and upper arm over welding and Rad PPE - rescue team -ROCO
  - rescue equipment includes personnel attachment points and ropes to engineered tie off point–ROCO
- Welding
  - calculations show that the copper vapor exposure is manageable when adequately ventilated
  - special TIP-TIG welder purchased to feed wire automatically and allow the weld to be done with one hand (following slides)
  - PPE –Respirator ½ or full-face (1/2 face was used)
  - Helium gas to minimize weld contamination and conduct heat (critical to success)
  - Leather PPE-jacket, arm sleeves, gloves, mask, goggles, flame resistant coveralls and hood, multiple leather welding blankets, high heat guards on guide arm
  - Hand trigger for welder and operator to adjust welder current and wire feed
  - radioactive surveys to determine rad levels prior to entry and during operation
  - chance of fire – minimum, fire watch on-hand with fire extinguisher



# Integrated Work Document IWD – Controls

- Breathing
  - Respirator two possibilities
  - ventilation to be supplied to generate a minimum of 1000 cfm at welder– use of blower to suck air through the tank
  - Communication -throat activated microphone to communicate to external personnel and Weld attendant operator (extensively used proven with mock-up and full dress rehearsal)
  - Multiple access points for equipment insertion, viewing and communication (frequency tuner ports upstream and downstream and post coupler ports at every drift tube centerline, ion pump; grate), lights, camera, sampling, small tools (extensively used previous 6 months)

# Miller Tip-Tig Welding Unit

- One Handed Operation
- Wire filler feed integral Tig Torch combination
- Ramped start and stop functions
- Full Current control
- Start and stop on hand control with welder



# Half Face Respirator and Miller Goggles and Hood Protection factor 10-Particulate and up to 13-UV



Electromagnetic Arc Sensor

# DuPont Proshield 6 SFR rating

## DuPont™ Tempro® for added protection

Designed to be worn over primary flame-resistant apparel, such as DuPont™ Nomex® or DuPont™ Protera®, DuPont™ Tempro® is a lightweight, disposable overgarment for use by workers in potentially flammable or electric arc environments.

DuPont™ Tempro® provides a barrier against the non-hazardous dirt, grease, grime and aerosols that these workers encounter every day, helping to protect and keep clean the primary flame-resistant garments that they wear.

In the event of an industrial fire or electric arc, DuPont™ Tempro® garments will not contribute to potential burn injury. They will not ignite and continue to burn when the flame source is removed.



# UniTech Service Group 4AFR (Anti-C and Flame Resistant)

## UniTech Flame-Resistant Coveralls

Created by applying a chemically reacted finish to an 88% cotton/12% nylon blend material. The result is soft and comfortable coveralls with excellent flame resistance that is retained for the life of the garment. The coveralls feature a brass zipper front, a breast pocket and a dosimeter tab. The 7.4 oz/yd<sup>2</sup> material has an 8 ATPV or greater value, which exceeds NFPA 70E requirements for class 2, electrical safety in the workplace.



# Miller welding goggles with 1/2 face respirator and full face welding mask and respirator



# Rescue Techniques Practiced In Mock-UP

- Several Standard Harnesses were tried but collided with Drift Tubes and were not ideal retrieval points
- Upper Arm and Ankle Retrieval were the most effective and allowed the welder movement to be successful welding
- Full Dress Rehearsal in Tank



# Weld Positions goggles and ½ and Full-face Days and Days of Practice, Including Rescue in Mock-Up and Full Dress Rehearsal in Tank





# Welder and Rescue Team Just Prior to Entry



# Welder In Position for Welding

- Tig Torch, lights, camera, sample monitoring are inserted through Slug Tuner and Post coupler Ports at the Repair Area



# Good news


- The Copper Bridge Welded as Expected from the Many Practice Welds Conducted



# Bad News-Good News!



- Crack Opened on Opposite Side
- We Welded Over to Top and Sealed it



# Guiding Documents

- AOT-MDE-IWD-19-001, DTL Tank 3 Inspection, Clean Out and Repair
- AOT-MDE-IWD-19-011, SOW, Tank Welding Repair, Module 3
- 29 CFR 1926 Subpart J, Welding 1926.353(a)(2)
- ANSI Z49.1:2012 Safety in Welding Cutting and Allied Processes, Section 7.1 Ventilation in Confined Spaces
- Radiation Work Plan: RWP 19-XXXX
- LANL Policy P121, Radiation Protection
- LANL Policy P101-27, Confined Spaces
- LANL Policy P101-27, Confined Space Entry Permit
- LANL Policy P101-27, Confined Space Rescue Plan
- LANL Policy P101-25, Cranes, Hoists, Lifting Devices, and Rigging Equipment
- LANL Policy P101-26, Welding, Cutting, and Other Spark- or Flame-Producing Operations
- LANL Policy P101-26, Attachment A. Form 1563, Spark- Or Flame-Producing Operations Permit
- Air flow calculation email from Industrial Hygiene

# Review and Preparation was Rigorous

- Most of these slides were presented at a Rehearsal of Concept (ROC) meeting
- Audience included safety professionals from all of LANL
  - Welding experts
  - Industrial Hygiene experts
  - Radiation protection experts
  - Rescue Experts
  - DOE Site Office Participation
  - Every Manager under the sun, but the local management owned it

# Weld Repair Was a Complete Success

- Welder Received a total of 33 mrem of exposure for month of July
- Welder spent a total of just shy of 11 hours inside the tank, total welding time just short of 1 hour
- Contamination was nda for entire job for all workers and work area smears
- Full Beam Production at 120 Hz, Declared August 21 at 15:00
- LANSCE Man of the Year “Jason Burkhart” Welder

# The (partial) Cast

|                   |                  |                  |
|-------------------|------------------|------------------|
| Jason Burkhart    | Michael Martinez | Nathan Garcia    |
| Michael Borden    | Buck Wilds       | John Bernal      |
| Stephen Milton    | Dick Bingham     | Sylvie Adam      |
| Denise Gelston    | Hargis James     | Dennis Ortiz     |
| Kevin Andrews     | Brian Adkison    | Brian Smith      |
| Paul Martin       | Samuel Bigger    | David Bell       |
| Mark Kirshner     | Brian Moore      | Alfred Maestas   |
| John Chamberlin   | Richard Pohl     | Robert Moore     |
| Walter Barkley    | Terry Morrison   | Danny Evans      |
| Michael Lake      | John Lyles       | Tsuyoshi Tajima  |
| Brandon Roller    | Michael Duran    | Ray Valicenti    |
| Mark Gulley       | Robert Brennecke | Anju Poudel      |
| David Ballard     | Josh Brito       | James O'Hara     |
| Francesca Pacheco | Nathan Kollarik  | David Bingham    |
| Mario Pacheco     | Michael Romero   | Kelly Bingham    |
| Gus Sinnis        | Aaron Adair      | Rebecca Williams |
| Aaron Walker      | Brandon Atencio  | James Vigil      |
| Matt Hardy        | Peter Plowman    | Kenneth Lucero   |
| Stephen Porto     | Manuel Soliz     |                  |